

REQUEST FOR INFORMATION

NUMBER: 007

DATE: 08-14-09

<p><u>OWNER: SUBMITTED TO:</u></p> <p>Scott Campbell SG Development 1500 Waters Ridge Drive Lewisville, Texas 76208</p>	<p><u>PROJECT NAME:</u></p> <p>STONEGATE SKILLED NURSING FACILITY OF LAWTON 7502 Quanah Parker Trailway Lawton, Oklahoma 73505 Randy Thomas - Superintendent - 918-760-8053</p>
<p>Stephen L. Jordan - Wayne Watson Stephen L. Jordan and Associates 4189 E. Mission Blvd. Fayetteville, Arkansas Phone: 479.444.9923 Fax: 479.444.9924 E-mail: sjordan@jordanandassociates.com</p>	<p><u>SUBMITTED BY:</u></p> <p>Erin Sherman ARTHUR CONSTRUCTION COMPANY, INC 7767 Burkburnett Road Wichita Falls, Texas 76305 Phone: 940.851.0022 Fax: 940.851.8900 Cell: 940.704.9404 Erin@accitexas.com</p>

SUBJECT: **Select Fill**

INFORMATION REQUESTED

Detail 3 on page S6 concerning the elevation. The porch & the finish floor are exactly the same. This also affects the bay window reference to detail 5 on page AD-1. Just clarification on how to proceed.

RESPOND TO: Fax - 940.851.8900 Erin@accitexas.com

RESPONSE - OWNER/ARCHITECT

Detail 3 on S-6 is correct. The porch and finish floor will be at the same elevation, however, there is a 5 1/2" wide x 1 1/2" deep "brick ledge" where brick occurs so the brick will course out with adjoining brick. Detail 5 on AD-1 is drawn incorrectly and should show a 5 1/2" x 1 1/2" deep brick ledge.

REQUESTED BY:

Erin Sherman
ARTHUR CONSTRUCTION COMPANY

ANSWERED BY - ARCHITECT:

Wayne Watson
Jordan & Associates