

REQUEST FOR INFORMATION

NUMBER: 09

DATE: 08-14-09

<p>OWNER: SUBMITTED TO:</p> <p>Scott Campbell SG Development 1500 Waters Ridge Drive Lewisville, Texas 76208</p>	<p>PROJECT NAME:</p> <p>STONEGATE SKILLED NURSING FACILITY OF LAWTON 7502 Quanah Parker Trailway Lawton, Oklahoma 73505 Randy Thomas - Superintendent - 918-760-8053</p>
<p>Stephen L. Jordan - Wayne Watson Stephen L. Jordan and Associates 4189 E. Mission Blvd. Fayetteville, Arkansas Phone: 479.444.9923 Fax: 479.444.9924 E-mail: sjordan@jordanandassociates.com</p>	<p>SUBMITTED BY:</p> <p>Erin Sherman ARTHUR CONSTRUCTION COMPANY, INC 7767 Burkburnett Road Wichita Falls, Texas 76305 Phone: 940.851.0022 Fax: 940.851.8900 Cell: 940.704.9404 Erin@accitexas.com</p>
<p>SUBJECT: 18" HDPE Storm Drain</p>	
<p>INFORMATION REQUESTED</p> <p>Can you please provide the tile size for the bathroom so that the slope can be accurately calculated</p>	
<p>RESPOND TO: Fax - 940.851.8900 Erin@accitexas.com</p>	
<p>RESPONSE - OWNER/ARCHITECT</p> <p>The tile is 2"x2". We much prefer at least 6"x6" or even 12"x12" if it would work, but that slope is hard to do with anything larger than 2x2 and make a smooth transition A good flooring guy may be able to make it work with larger tile, but just assume 2" for now. There is also nothing wrong with making your recess 12" out in front of the shower to accommodate multiple tile sizes. It's not that much more mud for the flooring guy</p>	
<p>REQUESTED BY:</p> <p>Erin Sherman ARTHUR CONSTRUCTION COMPANY</p>	<p>ANSWERED BY - ARCHITECT:</p> <p>Scott Campbell S&G Development</p>