

REQUEST FOR INFORMATION

NUMBER: 013

DATE: 08-27-09

<p>OWNER: SUBMITTED TO:</p> <p>Scott Campbell SG Development 1500 Waters Ridge Drive Lewisville, Texas 76208</p>	<p>PROJECT NAME:</p> <p>STONEGATE SKILLED NURSING FACILITY OF LAWTON 7502 Quanah Parker Trailway Lawton, Oklahoma 73505 Randy Thomas - Superintendent - 918-760-8053</p>
<p>Stephen L. Jordan - Wayne Watson Stephen L. Jordan and Associates 4189 E. Mission Blvd. Fayetteville, Arkansas Phone: 479.444.9923 Fax: 479.444.9924 E-mail: sjordan@jordanandassociates.com</p>	<p>SUBMITTED BY:</p> <p>Erin Sherman ARTHUR CONSTRUCTION COMPANY, INC 7767 Burkburnett Road Wichita Falls, Texas 76305. Phone: 940.851.0022 Fax: 940.851.8900 Cell: 940.704.9404 Erin@accitexas.com</p>
<p>SUBJECT: Gale Vents & Soffit Vents</p>	
<p>INFORMATION REQUESTED</p> <p>We would like to use perforated soffit instead of actual metal soffit vents and also we need more information on the gable vents (in vinyl we have 22" or 36") Do they have to be Lomanco Vents?</p>	
<p>RESPOND TO: Fax - 940.851.8900 Erin@accitexas.com</p>	
<p>RESPONSE - OWNER/ARCHITECT</p> <p>Perforated soffits are not allowed as it does not allow proper ventilation since the vents can not be within 4'-0" of a window, door or wall opening. Soffit vents do not have to be Lamanco but submit product information for the substitution. Gable vents are to be vinyl and 36" is acceptable.</p>	
<p>REQUESTED BY:</p> <p>Erin Sherman ARTHUR CONSTRUCTION COMPANY</p>	<p>ANSWERED BY - ARCHITECT:</p> <p>Wayne Watson Jordan & Associates</p>