

**REQUEST FOR INFORMATION**

**NUMBER: 024**

**DATE: 10-1-09**

<p><b>OWNER: SUBMITTED TO:</b></p> <p>Scott Campbell  <b>SG Development</b>          1500 Waters Ridge Drive          Lewisville, Texas 76208</p>	<p><b>PROJECT NAME:</b></p> <p><b>STONEGATE SKILLED NURSING FACILITY OF LAWTON</b>          7502 Quanah Parker Trailway          Lawton, Oklahoma 73505          Randy Thomas - Superintendent - 918-760-8053</p>
<p>Stephen L. Jordan - Wayne Watson  <b>Stephen L. Jordan and Associates</b>          4189 E. Mission Blvd.          Fayetteville, Arkansas          Phone: 479.444.9923          Fax: 479.444.9924          E-mail: <a href="mailto:sjordan@jordanandassociates.com">sjordan@jordanandassociates.com</a></p>	<p><b>SUBMITTED BY:</b></p> <p>Erin Sherman  <b>ARTHUR CONSTRUCTION COMPANY, INC</b>          7767 Burkburnett Road          Wichita Falls, Texas 76305          Phone: 940.851.0022          Fax: 940.851.8900          Cell: 940.704.9404 <a href="mailto:Erin@accitexas.com">Erin@accitexas.com</a></p>
<p><b>SUBJECT: Trench Drain</b></p>	
<p><b>INFORMATION REQUESTED</b></p> <p>Trench Drain cut on page P12 -2,show's a Length but Know Width,Need Width so we can get the Grate made</p>	
<p><b>RESPOND TO: Fax - 940.851.8900</b> <a href="mailto:Erin@accitexas.com">Erin@accitexas.com</a></p>	
<p><b>RESPONSE - OWNER/ARCHITECT</b></p> <p>Per C Section on sheet P-12, the width is 1'-4".</p>	
<p><b>REQUESTED BY:</b></p> <p>Erin Sherman          ARTHUR CONSTRUCTION COMPANY</p>	<p><b>ANSWERED BY - ARCHITECT:</b></p> <p>Wayne Watson          Jordan &amp; Associates</p>